



PRODUCT INFORMATION CONTINUED...

**staron**<sup>®</sup>  
Solid Surfaces

## EUROPEAN FIRE CLASSIFICATION

### "CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501 - 1:2002"

○ 12mm : Euroclass B – s1, d0

**4.2 Product Classification**

The Product, 12mm thick "STARON", in relation to its reaction to fire behaviour is classified:

**Reaction to fire classification: B-s1, d0**

**4.3 Field of application**

This classification is valid for the following end use applications:

- i) Wall or Ceiling Applications
- ii) Mounted without an air gap and directly onto any substrate with a density equal to or greater than 800kg/m<sup>3</sup>, with a minimum thickness of 12mm and a fire performance of A2 or better
- iii) With all joints sealed utilising 'STARON grade ADO2W' adhesive

This classification is also valid for the following product parameters:

Overall thickness	12 mm
Density	1.68g/cm <sup>3</sup>
Colour	Any

**SIGNED**

Leigh Hill  
Technical Officer  
Technical Department

**APPROVED**

Janet Murrell  
Technical Manager  
Technical Department  
on behalf of  
Warringtonfire

○ 6mm : Euroclass C – s1, d0

**4.2 Product Classification**

The Product, 6mm thick "STARON", in relation to its reaction to fire behaviour is classified:

**Reaction to fire classification: C-s1, d0**

**4.3 Field of application**

This classification is valid for the following end use applications:

- i) Wall or Ceiling Applications
- ii) Mounted without an air gap and directly onto any substrate with a density equal to or greater than 800kg/m<sup>3</sup>, with a minimum thickness of 6mm and a fire performance of A2 or better
- iii) With all joints sealed utilising 'STARON grade ADO2W' adhesive

This classification is also valid for the following product parameters:

Overall thickness	6 mm
Density	1.68g/cm <sup>3</sup>
Colour	Any

**SIGNED**

Leigh Hill  
Technical Officer  
Technical Department

**APPROVED**

Janet Murrell  
Technical Manager  
Technical Department  
on behalf of  
Warringtonfire



EUROPEAN FIRE CLASSIFICATION